

**Summary of ET Leader's Site Environmental Audit in the Reporting Month**

<b>Parameters</b>	<b>Date</b>	<b>Observations and Recommendations</b>	<b>Follow-up</b>
Air Quality	20 September 2024	Observation 1: The contractor should increase watering for the haul road.	Watering was increased.
Noise	10 September 2024	Observation 1: The Silentup at northwest of the site should be enclosed.	The Silentup was enclosed.
Water Quality	NA		
Chemical and Waste Management	NA		
Land Contamination	NA		
Ecological Impact	NA		
Landscape and Visual Impact	NA		
Permit / Licenses	10 September 2024	Reminder 1: The colour of NRMM label for the generator near AGS should be green.	A ner NRMM laber was provided
Others	NA		