

## Summary of ET Leader's Site Environmental Audit in the Reporting Month

### Contract DC/2019/10

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality		N/A	
Noise		NA	
Water Quality		NA	
Chemical and Construction Waste Management	10 February 2026	Observation 1: Drip tray should be provided for the fuel drum at SD.	Drip tray was provided for the fuel drum at SD.
Land Contamination		NA	
Ecological Impact		NA	
Landscape and Visual Impact		NA	
Permit / Licenses	4 February 2026	Observation 1: The color of NRMM label for the generator at AGS should be green.	A new NRMM label was provided.
Others		NA	

### Contract DE/2020/01

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality		NA	
Noise		NA	
Water Quality		NA	
Chemical and Construction Waste Management		NA	
Land Contamination		NA	
Ecological Impact		NA	
Permit / Licenses		N/A	
Others		NA	