

### Summary of ET Leader's Site Environmental Audit in the Reporting Month

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality		NA	
Noise		NA	
Water Quality	20 Apr 2023	Recommendation 1: The Contractor is recommended to provide mitigation measures to intercept silty runoff from the piling area at STB (Portion 1 - YLSTW).	26 Apr 2023
Chemical and Waste Management	4 Apr 2023	Reminder 1: The Contractor is reminded to provide drip tray for chemical containers to prevent chemical leakage (Portion 1 - YLSTW).	5 Apr 2023
	11 Apr 2023	Reminder 1: The Contractor is reminded to provide drip tray for chemical containers to prevent spillage (Portion 1 - YLSTW).	12 Apr 2023
Land Contamination		NA	
Ecological Impact		NA	
Landscape and Visual Impact		NA	
Permit / Licenses		NA	
Others		NA	