

## Summary of ET Leader's Site Environmental Audit in the Reporting Month

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality		NA	
Noise	9 Aug 2022	Reminder 1: The Contractor is reminded to maintain and reinstate the silentup at western and northern site boundary (Portion 1 - YLSTW).	NA
Water Quality	31 Aug 2022	Reminder 1: The Contractor is reminded to provide sandbags to prevent runoff into storm drain near piling area (Portion 1 - YLSTW).	NA
Chemical and Waste Management	17 Aug 2022	Observation 1: Clean up the oil stain on road with chemical absorbent pad and treat it as chemical waste for disposal (Portion 1 - YLSTW).	18 Aug 2022
Land Contamination		NA	
Ecological Impact		NA	
Landscape and Visual Impact	9 Aug 2022	Recommendation 1: Stockpile to be removed from tree protection zone beside the temporary admin office (MIC) (Portion 1 - YLSTW).	NA
	17 Aug 2022	Observation 1: Please keep tree protection zone free of construction material beside the temporary admin office (MIC) (Portion 1 - YLSTW).	26 Aug 2022
		Recommendation 1: <i>Ficus microcarpa</i> at eastern / northern edge of site are observed with "朱紅毛斑蛾", please liaise with relevant maintenance parties for pest control (Portion 1 - YLSTW).	NA
	24 Aug 2022	Observation 1: Please keep tree protection zone clear of construction material outside MIC area (Portion 1 - YLSTW).	26 Aug 2022
Permit / Licenses		NA	
Others		NA	