

Summary of ET Leader's Site Environmental Audit in the Reporting Month

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality		NA	
Noise	6 Jul 2022	Reminder 1: The Contractor is reminded to properly maintain the function of the noise barriers and silentup at the northern and western site boundary (Portion 1 - YLSTW).	NA
	12 Jul 2022	Reminder 1: The Contractor is reminded to properly maintain the function of the noise barriers and silentup at the northern and western site boundary (Portion 1 - YLSTW).	NA
Water Quality	12 Jul 2022	Reminder 1: The Contractor is reminded to provide sand bags to prevent silty runoff into the storm drains (Portion 1 - YLSTW).	NA
Chemical and Waste Management		NA	
Land Contamination		NA	
Ecological Impact	12 Jul 2022	Reminder 1: The Contractor is reminded to maintain and reinstate the bird curtains at the eastern and northern site boundary (Portion 1 - YLSTW).	NA
	20 Jul 2022	Reminder 1: The Contractor is reminded to maintain and reinstate the bird curtains at the eastern and northern site boundary (Portion 1 - YLSTW).	NA
Landscape and Visual Impact	27 Jul 2022	Recommendation 1: Please keep Tree Protection Zone clear of construction material (Portion 1 - YLSTW).	NA
Permit / Licenses		NA	
Others		NA	