

Summary of ET Leader's Site Environmental Audit in the Reporting Month

Parameters	Date	Observations and Recommendations	Follow-up
Air Quality	3 Nov 2021	Reminder 1: The Contractor is reminded to cover the excavated soil properly with tarpaulin sheets to prevent dust emission (Portion 1 – YLSTW).	3 Nov 2021
	30 Nov 2021	Reminder 1: The Contractor is reminded to increase watering for dust suppression at loading/unloading area (Portion 1 – YLSTW).	30 Nov 2021
Noise	NA		
Water Quality	NA		
Chemical and Waste Management	24 Nov 2021	Observation 1: Clean up the oil stain on road in front of Methane Compressor House with chemical absorbent pad and treat it as chemical waste for disposal (Portion 1 – YLSTW).	24 Nov 2021
Land Contamination	NA		
Ecological Impact	NA		
Landscape and Visual Impact	3 Nov 2021	Recommendation 1: Keep area around retained trees clear of construction material as far as possible (Portion 1 – YLSTW).	4 Nov 2021
	17 Nov 2021	Recommendation 1: Keep tree protection zone clear of construction equipment / tools (Portion 1 – YLSTW).	17 Nov 2021
	30 Nov 2021	Recommendation 1: Keep tree protection zone free of stockpiling or construction materials (Portion 1 – YLSTW).	1 Dec 2021
Permit / Licenses	NA		
Others	NA		